



June 18, 2026

UPDATE – QUESTIONS ABOUT TRACPIPE EXPOSED TO FLOODWATERS / SUBMERGED IN WATER OR OTHER LIQUIDS

TracPipe® and TracPipe® AP are manufactured from 300 series stainless steel.

Floodwater and water or liquid from other sources can contain chemicals or contaminants that are corrosive to the GAS PIPING SYSTEM, INCLUDING the RIGID STEEL PIPE AND Corrugated Stainless Steel Tubing (CSST) portions.

TracPipe or TracPipe AP AND ALL RIGID STEEL PIPE COMPONENTS IN THE PIPING SYSTEM that have been exposed to or submerged in these waters/liquids, must be replaced.

Other gas equipment should be thoroughly inspected, and their manufacturer contacted before returning them to service.