



December 5, 2012

UPDATE - QUESTIONS ABOUT TRACPIPE EXPOSED TO FLOODWATERS

TracPipe® and TracPipe® CounterStrike® are manufactured from 300 series stainless steel. Floodwaters contain chemicals or contaminants that are corrosive to THE GAS PIPING SYSTEM, INCLUDING the RIGID STEEL PIPE AND CORRUGATED stainless steel gas piping system.

TracPipe or TracPipe CounterStrike AND ALL RIGID STEEL PIPE COMPONENTS IN THE PIPING SYSTEM that have been exposed to flood water, must be replaced.

Other gas equipment should be thoroughly inspected and their manufacturer contacted before returning them to service.